SMOKE OR FIRE IN THE COMPUTER ROOM 1275
HALON IN MANUAL MODE

If it is <u>not safe</u>, **Exit** the computer room through the **nearest** exit.

IF THIS OCCURS:		DO THIS:	OR DO THIS:

BLUE STROBE & PULSATING HORN	**LEVEL 1 ALARM**
	• HSSD level 1 or 2, (low or medium levels of smoke)
	• HSSD level 2, Blowers are shut down
		SMOKE OR FIRE? Activate fire alarm.
		  Locate source
		  Remove power to system (EPO if necessary)
		FIRE REMAINS AFTER POWER REMOVED?
		  Use extinguisher if it is safe to do so
		NEED IMMEDIATE HALON RELEASE?
		  Pull Halon MANUAL RELEASE; exit room
		  MANUAL MODE will not allow automatic Halon release
			IS THE ISSUE RESOLVED?
			
			You know what caused this alarm and the cause (short circuit, dusty work) has been resolved, or does not require Halon release

BLUE AND YELLOW STROBES, & PULSATING HORN	**LEVEL 2 ALARM**
	• HSSD level 3 (high level of smoke)
	• Lieberts shut down
	• EPO activated
		FIRE REMAINS AFTER AUTO EPO?
		  Use extinguisher if it is safe to do so
		NEED IMMEDIATE HALON RELEASE?
		  Pull Halon MANUAL RELEASE; exit room
		  MANUAL MODE will not allow automatic Halon release
			Stay near HALON ABORT BUTTON
			
			If red strobe and continuous horn activated, PRESS AND HOLD Halon ABORT BUTTON

RED STROBE & CONTINUOUS HORN ONLY AFTER MANUAL RELEASE	**LEVEL 3 ALARM**
	• Halon release in 30 seconds
	• building alarm activated
		HALON RELEASE NEEDED?
		  MANUAL MODE will not allow automatic Halon release
		  Pull Halon MANUAL RELEASE; exit room
		HALON RELEASE IN 30 SECONDS!
		  Exit computer room
			Call Alameda County Fire Dept x31051 or 510-486-6015 and report this information

FIRE ALARM BELL & CLEAR STROBE	**BUILDING FIRE ALARM**	**NO OTHER STROBES FLASHING; NO PULSATING HORNS?**
		  Most likely a fire alarm has been activated elsewhere in the building
		  Stop work and exit the building	